

2024 Annual Drinking Water Quality Report

Wilson County Southeast Water District

Water System Number: 40-98-014

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about your sources of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact Wilson County Water Services at (252) 399-2749. We want our valued customers to be informed about their water utility.**

What the EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

When You Turn on Your Tap, Consider the Source

The water used by this system is ground water purchased from the Town of Stantonsburg as well as surface water from The City of Wilson.

Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environment and Natural Resources (DENR), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for the Town of Stantonsburg and the City of Wilson was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). Please see the complete SWAP Assessment report for the Southwest District's water sources, the Town of Stantonsburg (groundwater) and the City of Wilson (surface water) on the Web at: www.ncwater.org/pws/swap.

System Name	Wilson Co Southwest Water Dist.
City	Wilson
PWS ID	NC4098012
Source Name	Stantonsburg, Town of
Source Name	Wilson, City of

Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this web site may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to swap@ncdenr.gov. Please indicate your system name, number, and provide your name, mailing address and phone number.

If you have any questions about the SWAP report, please contact the Source Water Assessment staff by phone at 919-707-9098.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the system’s potential to become contaminated by Potential Contaminant Sources (PCSs) in the assessment area.

Help Protect Your Source Water

Protection of drinking water is everyone’s responsibility. You can help protect your community’s drinking water sources in several ways. Use and dispose of harmful materials and chemicals properly. Avoid dumping hazardous waste such as motor oil, pesticides, household cleaners, etc. down the drain, on the ground or in stormwater drains. Doing so can contaminate the soil, groundwater and nearby surface waters.

Violations that Your Water System Received for the Report Year

We are pleased to announce that Wilson County’s Southeast Water District had no violations for the 2024 reporting year.

Important Drinking Water Definitions

- **Action Level (AL)** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **Locational Running Annual Average (LRAA)** – The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.
- **Maximum Contaminant Level (MCL)** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **Maximum Contaminant Level Goal (MCLG)** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Residual Disinfection Level (MRDL)** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Maximum Residual Disinfection Level Goal (MRDLG)** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Million Fibers per Liter (MFL)** - Million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.
- **Non-Detects (ND)** - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.
- **Not-Applicable (N/A)** – Information not applicable/not required for that particular water system or for that particular rule.
- **Parts per billion (ppb) or Micrograms per liter (ug/L)** - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
- **Parts per million (ppm) or Milligrams per liter (mg/L)** - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Water Quality Data Tables of Detected Contaminants

We routinely monitor contaminants in your drinking water according to Federal and State laws. The tables below list all the drinking water contaminants that we detected in the last round of sampling for each particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2024.** The EPA and the State allow us to monitor certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Lead and Copper

Contaminant (units)	Sample Date	Your Water	Number of sites found above the action level	MCLG	Action Level (AL)	Likely Source of Contamination
Copper (ppm) (90 th percentile)	07/2022	0.091	0	1.3	AL = 1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb) (90 th percentile)	07/2022	Non-Detected	0	0	AL = 15	Corrosion of household plumbing systems, erosion of natural deposits

The table above summarizes our most recent lead and copper tap sampling data. Compliance with the lead and copper actions levels is based on the 90th percentile lead and copper levels. This means that the concentration of lead and copper must be less than or equal to the action level in at least 90% of the samples collected. If you would like to review the complete lead tap sampling data, please call Wilson County's Water Services Department at (252) 399-2749 or email rford@wilsoncountync.gov.

Lead Service Line Inventory (LSLI)

We have been working to identify service line materials throughout the water system and prepared an inventory of all service lines in our water system. To access this inventory, please submit your request by calling Wilson County's Water Services Department at (252) 399-2749 or email rford@wilsoncountync.gov.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Wilson County Water Services is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Wilson County Water Services Department at (252) 399-2749. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Total Trihalomethanes (TTHM) and Haloacetic Acids (five) (HAA5)

Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Your Water (Location)	Range Low - High	MCLG	MCL (ppb)	Likely Source of Contamination
TTHM (ppb)	2024	NO	B01 – 29 ppb B02 – 9 ppb	N/A	N/A	80	Byproduct of drinking water disinfection
HAA5 (ppb)	2024	NO	B01 – 7 ppb B02 – 2 ppb	N/A	N/A	60	Byproduct of drinking water disinfection

Disinfectant Residuals Summary

Disinfectant	Year Sampled	MRDL Violation Y/N	Your Water (Highest RAA)	Range Low - High	MRDLG	MRDL	Likely Source of Contamination
Chlorine (ppm)	2024	NO	0.91	0.7 - 1.1	4	4.0	Water additives are used to control microbes.

Asbestos Contamination

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low - High	MCLG	MCL	Likely Source of Contamination
Total Asbestos (MFL)	12/3/2013	NO	Non - Detected	Non - Detected	7	7	Decay of Asbestos Cement water mains. Erosion of natural deposits

Microbiological Contaminants in the Distribution System : For systems that collect less than 40 samples per month.

Contaminant (units)	MCL Violation Y/N	Your Water	MCLG	MCL	Likely Source of Contamination
Total Coliform Bacteria (presence or absence)	NO	Absent	0	One positive monthly sample	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (presence or absence)	NO	Absent	0	Note: The MCL is exceeded if a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or <i>E. coli</i> positive	Human and animal fecal waste

2024 Annual Drinking Water Quality Report

Town of Stantonsburg

Water System Number: NC 04-98-025

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is a snapshot of last year's water quality. Included are details about your source(s) of water, what it contains, and how it compares to standards set by regulatory agencies. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water and to providing you with this information because informed customers are our best allies. **If you have any questions about this report or concerning your water, please contact Brain Hawley (Town Manager) at (252) 238-3608, or Roger Sullivan (Chief Utilities Systems Operator) at (252) 414-7800. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the second Monday after the third day of the month beginning at 7:00 pm at the Town Hall.**

What EPA Wants You to Know

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

When You Turn on Your Tap, Consider the Source

The water that is used by this system is groundwater from five wells. Well # 1 is located on Commercial Avenue Extension, Well # 2 is located on Peacock Bridge Road/SR1540, Well # 3 is located between Peacock Bridge Rd. and the Town's Wastewater Treatment Facility, Well # 4 is located at 107-B Shelton Ave. and Well # 5 is located at Moyton Ave. All wells draw from the Upper Cape Fear Aquifer.

Source Water Assessment Program (SWAP) Results

The North Carolina Department of Environmental Quality (DEQ), Public Water Supply (PWS) Section, Source Water Assessment Program (SWAP) conducted assessments for all drinking water sources across North Carolina. The purpose of the assessments was to determine the susceptibility of each drinking water source (well or surface water intake) to Potential Contaminant Sources (PCSs). The results of the assessment are available in SWAP Assessment Reports that include maps, background information and a relative susceptibility rating of Higher, Moderate or Lower.

The relative susceptibility rating of each source for **Town of Stantonsburg** was determined by combining the contaminant rating (number and location of PCSs within the assessment area) and the inherent vulnerability rating (i.e., characteristics or existing conditions of the well or watershed and its delineated assessment area). The assessment findings are summarized in the table below:

Source Name	Susceptibility Rating	SWAP Report Date
Well # 1	Moderate	September 10, 2020
Well # 2	Moderate	September 10, 2020
Well # 3	Moderate	September 10, 2020
Well # 4	Lower	September 10, 2020
Well # 5	Moderate	September 10, 2020

The complete SWAP Assessment report for **Town of Stantonsburg** may be viewed on the Web at: <https://www.ncwater.org/?page=600> Note that because SWAP results and reports are periodically updated by the PWS Section, the results available on this website may differ from the results that were available at the time this CCR was prepared. If you are unable to access your SWAP report on the web, you may mail a written request for a printed copy to: Source Water Assessment Program – Report Request, 1634 Mail Service Center, Raleigh, NC 27699-1634, or email requests to swap@deq.nc.gov. Please indicate your system name, number, and provide your name, mailing address and phone number. If you have any questions about the SWAP report, please contact the Source Water Assessment staff by phone at (919) 707-9098.

It is important to understand that a susceptibility rating of “higher” does not imply poor water quality, only the system’s potential to become contaminated by PCSs in the assessment area.

Help Protect Your Source Water

Protection of drinking water is everyone’s responsibility. We have implemented the following source water protection actions: You can help protect your community’s drinking water source(s) in several ways: (examples: dispose of chemicals properly; take used motor oil to a recycling center, volunteer in your community to participate in group efforts to protect your source, etc.).

Important Drinking Water Definitions:

- ***Not-Applicable (N/A)*** – Information not applicable/not required for that particular water system or for that particular rule.
 - ***Non-Detects (ND)*** - Laboratory analysis indicates that the contaminant is not present at the level of detection set for the particular methodology used.
 - ***Parts per million (ppm) or Milligrams per liter (mg/L)*** - One part per million corresponds to one minute in two years or a single penny in \$10,000.
 - ***Parts per billion (ppb) or Micrograms per liter (ug/L)*** - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.
 - ***Parts per trillion (ppt) or Nanograms per liter (nanograms/L)*** - One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.
 - ***Parts per quadrillion (ppq) or Picograms per liter (picograms/L)*** - One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.
 - ***Picocuries per liter (pCi/L)*** - Picocuries per liter is a measure of the radioactivity in water.
 - ***Million Fibers per Liter (MFL)*** - Million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.
 - ***Nephelometric Turbidity Unit (NTU)*** - Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
 - ***Variations and Exceptions*** – State or EPA permission not to meet an MCL or Treatment Technique under certain conditions.
 - ***Action Level (AL)*** - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
 - ***Treatment Technique (TT)*** - A required process intended to reduce the level of a contaminant in drinking water.
 - ***Maximum Residual Disinfection Level (MRDL)*** – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
 - ***Maximum Residual Disinfection Level Goal (MRDLG)*** – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
 - ***Locational Running Annual Average (LRAA)*** – The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.
 - ***Running Annual Average (RAA)*** – The average of sample analytical results for samples taken during the previous four calendar quarters.
 - ***Level 1 Assessment*** - A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
 - ***Level 2 Assessment*** - A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
 - ***Maximum Contaminant Level (MCL)*** - The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
 - ***Maximum Contaminant Level Goal (MCLG)*** - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
-

Water Quality Data Tables of Detected Contaminants

We routinely monitor for over 150 contaminants in your drinking water according to Federal and State laws. The tables below list all the drinking water contaminants that we detected in the last round of sampling for each particular contaminant group. The presence of contaminants does not necessarily indicate that water poses a health risk. **Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2024.** The EPA and the State allow us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Lead and Copper Contaminants

Contaminant (units)	Sample Date	Your Water (90 th Percentile)	Number of sites found above the AL	Range		MCLG	AL	Likely Source of Contamination
				Low	High			
Copper (ppm) (90 th percentile)	7/6/22	0.145 (ppm)	0	0.00 (ppm)	0.20 (ppm)	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb) (90 th percentile)	7/6/22	0.00 (ppb)	0	0.00 (ppb)	13.0 (ppb)	0	AL=15	Corrosion of household plumbing systems; erosion of natural deposits

The table above summarizes our most recent lead and copper tap sampling data. If you would like to review the complete lead tap sampling data, please email us at roger@townofstantonsburg.com

We have been working to identify service line materials throughout the water system and prepared an inventory of all service lines in our water system. To access this inventory, **a hardcopy will be made available for view at Town Hall.**

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. **Town of Stantonburg** is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact **Town of Stantonburg at (252) 238-3608**. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Exposure to lead in drinking water can cause serious health effects in all age groups. Infants and children can have decreases in IQ and attention span. Lead exposure can lead to new learning and behavior problems or exacerbate existing learning and behavior problems. The children of women who are exposed to lead before or during pregnancy can have increased risk of these adverse health effects. Adults can have increased risks of heart disease, high blood pressure, kidney or nervous system problems.

Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's disease should consult their personal doctor.

Total Trihalomethanes (TTHM) and Haloacetic Acids (five) (HAA5)

Disinfection Byproduct	Year Sampled	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
TTHM (ppb)	2024	N	19 (ppb)	8 (ppb)	19 (ppb)	N/A	80	Byproduct of drinking water disinfection
HAA5 (ppb)	2024	N	3 (ppb)	1 (ppb)	3 (ppb)	N/A	60	Byproduct of drinking water disinfection

Disinfectant Residuals Summary

	MRDL Violation Y/N	Your Water (RAA)	Range		MRDLG	MRDL	Likely Source of Contamination
			Low	High			
Chlorine (ppm)	N	1.31 (ppm)	0.71 (ppm) - 1.76 (ppm)		4	4.0	Water additive used to control microbes

Inorganic Contaminants

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range		MCLG	MCL	Likely Source of Contamination
				Low	High			
Antimony (ppb)	7/11/24	N	4.0 (ppb)	4.0 (ppb)		6	6	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Arsenic (ppb)	7/11/24	N	6.9 (ppb)	6.9 (ppb)		0	10	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Fluoride (ppm)	7/11/24	N	0.25 (ppm)	0.17 (ppm) - 0.25 (ppm)		4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Selenium (ppb)	7/11/24	N	11.0 (ppb)	11.0 (ppb)		50	50	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines

The PWS Section requires monitoring for other misc. contaminants, some for which the EPA has set national secondary drinking water standards (SMCLs) because they may cause cosmetic effects or aesthetic effects (such as taste, odor, and/or color) in drinking water. The contaminants with SMCLs normally do not have any health effects and normally do not affect the safety of your water.

Other Miscellaneous Water Characteristics Contaminants

Contaminant (units)	Sample Date	Your Water	Range		SMCL
			Low	High	
Iron (ppm)	7/11/24	0.269 (ppm)	0.0204 (ppm) - 0.269 (ppm)		0.3
Manganese (ppm)	7/11/24	0.074 (ppm)	0.033 (ppm) - 0.074 (ppm)		0.05
Sodium (ppm)	7/11/24	41.276 (ppm)	31.366 (ppm) - 41.276 (ppm)		N/A
pH	7/11/24	7.7	7.2 - 7.7		6.5 to 8.5

2024 Annual Consumer Confidence Report Information for Wilson County
City of Wilson P.O. Box 10 Wilson, NC 27894
PWS I.D. # NC0498010

City of Wilson's Water Treatment Facilities

Turbidity*

Contaminant (Units)	Treatment Techniqu (TT) Violation if:	MCLG	Your Water	Water	Likely Source of Contamination	Treatment Technique (TT) Violation Y/N
Turbidity (NTU) - Highest Single Turbidity Measurement	Turbidity > 1 NTU	N/A	0.29	NTU	Soil runoff	NO
Turbidity (NTU) - Lowest Monthly Percentage (%) of Samples Meeting Turbidity Limits	Less than 95% of Onthly Turbidity Measurements are < 0.3 NTU	N/A	10	0%		

* Turbidity is a measure of the cloudiness of water. We monitor it because it is good indicator of the effectiveness of our filtration system. The turbidity rule that 95% or more of the monthly samples must be less than or equal to 0.3 NTU.

Inorganic Contaminants

Contaminant (Units)	Year Sampled	M	CL	MCLG	Your Water	Range Detected	Likely Source of Contamination	MCL Violation	Y/N
Fluoride (ppm)	2024		4	4	0.7	0.65 - 0.78	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories	NO	

Disinfection Byproduct Precursors Contamina

Contaminant	Year Sampled	MCLG	TT violation if:	Your Water (Lowest RAA)	Range (Monthly Removal Ratio Low-High)	Likely Source of Contamination	MCL Violation	Y/N
Total Organic Carbon (TOC) (Removal Ratio) - Treated Water	2024	N/A	Removal Ratio RAA <1.00	1.81	1.70 - 2.16	Naturally present in the environment	NO	

Stage 2 Disinfection Byproduct Compliance - Based upon Locational Running Annual Average (LRAA)

Disinfection Byproduct	Year Sampled	MCL	MCLG	Your Water (Highest LRAA)	Range Detected	Likely Source of Contamination	MCL Violation	Y/N
TTHM (ppb)	2024	80	N/A	63.5	8 - 101	By-product of drinking water disinfection	NO	
HAA5 (ppb)	2024	60	N/A	45.5	Dec-65	By-product of drinking water disinfection	NO	

Some people who drink water containing trihalomethanes in excess of the a MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer. Some people who drink water containing haloacetic acids in excess of the MCL over many years have an increased risk of getting cancer.

Disinfectant Residuals Summary

Contaminant (Units)	Year Sampled	MRDL	MRDLG	Your Water (RAA)	Range Detected	Likely Source of Contamination	MRDL Violation	Y/N
Chlorine (ppm)	2024	4	4	0.67	0.20 - 1.52	Water additive used to control microbes	NO	

Regulated at the Tap - Lead and Copper Contaminants

Contaminant (Units)	Year sampled	AL	MCLG	Your Water	Number of Sites Found Above AL	Likely Source of Contamination	MCL Violation	Y/N
Lead (ppb) (90 th Percentile)	2022	AL = 15	0	None Detected (90 th percentile)	1	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	NO	
Copper (ppm) (90 th Percentile)	2022	AL = 1.3	1.3	0.170 (90 th percentile)	0	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives	NO	

City of Wilson's Source Waters

The City of Wilson obtains its water supply from two sources. The first source is Contentnea Creek and consists of the Buckhorn Lake and the downstream Wiggins Mill Reservoir. Buckhorn Lake is the City's largest water supply reservoir and is an impoundment on the Contentnea Creek approximately 12 miles west of the city. Water is released from Buckhorn Lake into Contentnea Creek and is pumped from the downstream Wiggins Mill Reservoir to the Wiggins Mill Water Treatment Plant and to the Toisnot Water Treatment Plant. The other water supply source for the City is Toisnot Reservoir and consists of Lake Wilson and the downstream Toisnot Reservoir, which together provide water for the Toisnot Water Treatment Plant. A connection from the Tar River Reservoir to upstream of Lake Wilson is also available as a water supply during emergency conditions.

The complete SWAP Assessment report for the City of Wilson may be viewed on the web at: <https://www.ncwater.org/?page=600> (enter 0498010 for the City of Wilson).
Wiggins Mill: Higher & Toisnot: Moderate, Sept. 2020

TT Treatment Technique- A required process intended to reduce the level of a contaminant in drinking water.
AL Action Level- The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
MCL Maximum Contaminant Level- The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
MCLG Maximum Contaminant Level Goal- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MRDL Maximum Residual Disinfectant Level- The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MRDLG Maximum Residual Disinfectant Level Goal- The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
NA Not applicable- Information not applicable/not required for that particular water system or for that particular rule.
NTU Nephelometric Turbidity Units- Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
ppm parts per million- One part per million corresponds to one drop of water in a 13 gallon fish tank.
ppb parts per billion- One part per billion corresponds to one drop of water in a 13,000 gallon swimming pool.
ppt parts per trillion- One part per trillion corresponds to one drop of water in 20 olympic size swimming pools or 10,000,000 gallons of water.
RAA Running Annual Average- The average of sample analytical results for samples taken during the previous four calendar quarters.
LRAA Locational Running Annual Average- The average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters under the Stage 2 Disinfectants and Disinfection Byproducts Rule.